


# I don't want to move to the Arctic

-

## a HPC Data Center Take on PUE and Energy Efficiency

Torsten Wilde (LRZ), Detlef Labrenz (LRZ), iCAS'15, Annecy, France

**Facebook – Lulea, Sweden:  
120MW, PUE < 1.1**









## Some more Facts


- **3160.5 m<sup>2</sup> (34 019 ft<sup>2</sup>)** IT Equipment Floor Space (6 rooms on 3 floors)
- **6393.5 m<sup>2</sup> (68 819 ft<sup>2</sup>)** Infrastructure Floor Space
- **2 x 10 MW** 20kV Power Supply
- **Powered Entirely by Renewable Energy**
- **> 5M € (> 6M US\$)** Annual Power Bill

The Leibniz Supercomputing Centre



Nr. 20  
(Top500, July 2015)









Nr. 21  
(Top500, July 2015)



Phase 1  
3.2 PFLOP/s

# SuperMUC

Phase 2  
3.2 PFLOP/s






# The Arctic for Dummies



- Very good (low) Power Usage Effectiveness (PUE)
  - Chiller-less cooling for either air or water cooling
  - Reducing cooling overhead
- Low population density, cheap real estate
- Most stable renewable energy grid in the world (Hydroelectric, Wind)
  - Low energy prices



# The Cons - Snow, Snow, and ...








# Optimal PUE




- Good to assess overall data center overhead

$$PUE = \frac{\sum P_i}{P_{IT}} \quad \text{i: [IT, electrical power distribution and conversion losses, infrastructure, ...]}$$

- Does not determine if the IT power is efficiently used by IT systems
- Worst case:
  - One can very effectively waste a lot of energy
  - PUE  $\neq$  Efficiency (Costs)










- No other power consumption than  $P_{IT}$ 
  - Dark center, or only natural lighting
- No Electrical transmission losses
  - that's hard, maybe super-conductors
- No power consumed by cooling system
  - Passive cooling
- No resource usage (carbon, water)
  - 100% renewable energy (challenging with only solar and wind power)
  - no water consumption (evaporative cooling)





[http://mmu.ic.polyu.edu.hk/mu\\_proj/2011/ME/ME08/1.html](http://mmu.ic.polyu.edu.hk/mu_proj/2011/ME/ME08/1.html)



Zalman TNN500A



- Solar Panels on roof and south side (20% efficiency, 200W per 1m<sup>2</sup>):
  - South side: 70m x 33m = 2380m<sup>2</sup> => 476kW
  - Roof: 70m x 35m = 2450m<sup>2</sup> => 490kW
  - ~ 1MW
- Cooling area (4620m<sup>2</sup>):
  - North side: 70m \* 33m = 2310 m<sup>2</sup>
  - West and east side: (35m\*2) \* 33m = 2310 m<sup>2</sup>
  - ~ 125 kw (delta T 10°C like for water example later)
- With 1m long fins in 1m intervals (9273m<sup>2</sup>):
  - 1m\*33m\*141 = 4653 m<sup>2</sup>
  - ~ 1 MW (delta T 30°C)

# LRZ Cube With Heatsink and Fins (1m Distance, 1m Long) On North, East, and West Side With 30K delta T

Natural Convection Heat Transfer Coefficient Correlations (S.I. units)			Equations for Natural Convection - Isothermal Vertical Plane		
1. With an isothermal vertical plane			Fluid =	air	
<b>Inputs</b>			<b>Calculations</b>		
Fluid Temp, $T_{\infty}$ =	20	°C	Temp Diff, $\Delta T$ =	30	°C
Surface Temp, $T_w$ =	50	°C	Abs. Film Temp, $T_f$ =	308	°K
Film Temp., $T_f$ =	35	°C	Prandtl Number, Pr =	0,69	
[ $T_f = (T_{\infty} + T_w)/2$ ]					
Area of Plate, A =	9273,0	m <sup>2</sup>	Grashof Number, Gr =	1,19,E+14	
Height of Surf., L =	33,0	m	Rayleigh No., Ra =	8,23E+13	
Fluid Density, $\rho$ =	1,1	kg/m <sup>3</sup>			
<b>Correlation #1 ( for all values of Ra ):</b>					
Fluid viscosity, $\mu$ =	1,87E-05	N-s/m <sup>2</sup>	Nu =	4672	
Fluid Sp. Heat, $C_p$ =	1	J/g-°K	h =	3,82	W/m <sup>2</sup> -K
Fluid Sp. Heat, $C_p$ =	1000	J/kg-°K			
<b>Correlation #2 ( for RaL &lt; 10<sup>9</sup> ):</b>					
Fluid Thermal Conductivity, k =	0,027	J/s-m-K	Nu =	1545	
Fluid Thermal Expans. Coeff, $\beta$ =	0,003245	°K <sup>-1</sup>	h =	1,26	W/m <sup>2</sup> -K
NOTE: For the example shown, correlation #2 shouldn't be used, because Ra > 10 <sup>9</sup> .					
* For an Excel spreadsheet that can be downloaded to calculate the density of a gas with known molecular weight and specified temperature and pressure, see:					
"Excel Templates for Venturi and Orifice Flow Meter Calculations," at:			Q=	1063455	W
<a href="http://www.brighthub.com/engineering/civil/articles/83825.aspx">http://www.brighthub.com/engineering/civil/articles/83825.aspx</a>			<a href="http://www.brighthubengineering.com/hvac/92660-natural-convection-heat-transfer-coefficient-estimation-calculations">http://www.brighthubengineering.com/hvac/92660-natural-convection-heat-transfer-coefficient-estimation-calculations</a>		

$$Nu = \frac{h L}{k} \quad Pr = \frac{\mu C_p}{k}$$

$$Gr = \frac{L^3 \rho^2 g \Delta T \beta}{\mu^2}$$

$$Ra = GrPr$$

Dimensionless Numbers used in Natural Convection Heat Transfer Coefficient Correlations

**Correlation #1:**

for all values of Ra:

$$Nu = \left\{ 0.825 + \frac{0.387 Ra^{1/6}}{[1 + (0.492/Pr)^{9/16}]^{8/27}} \right\}^2$$

**Correlation #2:**

Slightly better for laminar flow ( Ra ≤ 10<sup>9</sup> ):

$$Nu = 0.68 + \frac{0.670 Ra^{1/4}}{[1 + (0.492/Pr)^{9/16}]^{4/9}}$$

Capacity:

**1 MW**





## Submarine Typhoon Class:

*length:* 175m (574 ft 2 in)

*draft:* 12 m (39 ft 4 in)

*volume displacement:* 33,270 long  
tones = 1164450 feet<sup>2</sup> (1 lt = 35 feet<sup>2</sup>)


*hull material:* titanium

*reactor:* two OK-650 reactors (each  
190MW)

*surface area estimate\*:* 67914 feet<sup>2</sup>  
(6309 m<sup>2</sup>)

\* According to the technical development document for Phase I Uniform National Discharge Standards for Vessels of the Armed Forces, Naval Sea Systems Command, US Department of the Navy:  $SA = 1.7*(L)*(D) + (V) / (D)$

# Baltic Sea Max Surface Temperature



Source: <http://www.helcom.fi/baltic-sea-trends/environment-fact-sheets/hydrography>



# Submarine Hull (6309 m<sup>2</sup>) heat transfer (30°C Hull temp -> 20 °C water temp)

	A	B	C	D	E	F	G	H	I	J	K	L	P	Q	R	S
1	Natural Convection Heat Transfer Coefficient Correlations (S.I. units)								Equations for Natural Convection - Isothermal Horizontal Cylinder							
2																
3	4. With an isothermal horizontal cylinder								Fluid = water							
4																
5	<b>Inputs</b>								<b>Calculations</b>							
6																
7	Fluid Temp, T <sub>∞</sub> =		20	°C		Temp Diff, ΔT =		10	°C							
8																
9	Surface Temp, T <sub>w</sub> =		30	°C		Abs. Film Temp, T <sub>f</sub> =		298	°K							
10																
11	Film Temp., T <sub>f</sub> =		25	°C		Prandtl Number, Pr =		5,43								
12	[ T <sub>f</sub> = (T <sub>∞</sub> + T <sub>w</sub> )/2 ]															
13																
14	Cylinder Diam., D =		11,1	m		Grashof Number, Gr =		6,36,E+13								
15	Cylinder Surface, A =		6309	m <sup>2</sup>		Rayleigh No., Ra =		3,46E+14								
16	Fluid Density, ρ* =		995,7	kg/m <sup>3</sup>												
17																
18	Fluid viscosity, μ =		7,980E-04	N-s/m <sup>2</sup>												
19																
20	Fluid Sp. Heat, C <sub>p</sub> =		4,179	J/g-°K		Nu =		9201								
21																
22	Fluid Sp. Heat, C <sub>p</sub> =		4179	J/kg-°K		h =		503,90	W/m <sup>2</sup> -K							
23																
24	Fluid Thermal															
25	Conductivity, k =		0,609	J/s-m-K												
26																
27	Fluid Thermal															
28	Expans. Coeff, β =		3,03E-04	°K <sup>-1</sup>												
29																
30	* For an Excel spreadsheet that can be downloaded to calculate the density of a gas															
31	with known molecular weight and specified temperature and pressure, see:															
32	"Excel Templates for Venturi and Orifice Flow Meter Calculations," at															
33	<a href="http://www.briqthub.com/engineering/civil/articles/83825.aspx">http://www.briqthub.com/engineering/civil/articles/83825.aspx</a>															
34																

$$Nu = \left\{ 0.60 + \frac{0.387 Ra^{1/6}}{[1 + (0.559/Pr)^{9/16}]^{8/27}} \right\}^2$$

$$Gr = \frac{D^3 \rho^2 g \Delta T \beta}{\mu^2} \quad Nu = \frac{h D}{k} \quad Pr = \frac{\mu C_p}{k}$$

for Ra ≤ 10<sup>12</sup> (Ra = Gr Pr)

Natural Convection Heat Transfer from an Isothermal Horizontal Cylinder

### Cylinder estimation:

- d = 11,122m
- h = 175m
- A= 6309 m<sup>2</sup>

Good news:  
**31.8MW** (submerged)

<http://www.briqthubengineering.com/hvac/92660-natural-convection-heat-transfer-coefficient-estimation-calculations>

Water properties taken from:

- [http://www.engineeringtoolbox.com/water-thermal-properties-d\\_162.html](http://www.engineeringtoolbox.com/water-thermal-properties-d_162.html)
- [http://www.engineeringtoolbox.com/water-dynamic-kinematic-viscosity-d\\_596.html](http://www.engineeringtoolbox.com/water-dynamic-kinematic-viscosity-d_596.html)



# LRZ System PUE SuperMUC




$$PUE = \frac{P_{IT} + P_{PDCL} + P_{Cooling}}{P_{IT}} = 1 + \frac{P_{PDCL}}{P_{IT}} + \frac{P_{Cooling}}{P_{IT}} = 1 + \text{Overhead}_{PDCL} + \frac{P_{Cooling}}{P_{IT}}$$


- By moving to cooler climates  $P_{Cooling}$  is reduced (no chillers)
- Low power density (5-12kw per rack<sup>\*</sup>) is optimal for air cooling (SuperMUC Phase1 20kW per rack, SuperMUC Phase2 25kW per rack)
  - Power consumption of air cooling equipment (fans) in racks count as  $P_{IT}$
  - Increasing air inlet temperatures for IT equipment reduces  $P_{Cooling}$  and increases  $P_{IT}$
- Control over full data center and specialized use-case allows hardware redundancy to move to software redundancy, reducing  $\text{Overhead}_{PDCL}$
- Using full load condition for PUE calculation maximizes  $P_{IT}$
- **All this allows for a leading PUE of less than 1.1** (Side note: besides Google, nobody explained in full detail how PUE is measured)

\* [http://www.opencompute.org/assets/open-rack/Open\\_Compute\\_Project\\_Open\\_Rack\\_v1.0.pdf](http://www.opencompute.org/assets/open-rack/Open_Compute_Project_Open_Rack_v1.0.pdf)




## Power Profile LRZ 2014 (uptime only)






# SuperMUC Colling Overhead Comparison (Total vs Warm Water)





## Power&Cooling Overhead SuperMUC 2014 (uptime only)




- Use “designed load” as  $P_{IT}$  for PUE
  - Restricting data to SuperMUC power consumption > 2.0 MW (could be as high as 3.6MW for Linpack 😊 )
  - **SuperMUC PUE: 1.20**
- Remove all UPS equipment (can remove the 8% off power distribution overhead)
  - **SuperMUC PUE: 1.12 – very close to arctic data center PUE’s**



# Data Center Sustainability - Benefits of Direct Hot Water Cooling



# Air vs Direct Liquid Cooling



## CoolMUC (178 nodes):

Measurement for single node

- two AMD Opteron 6128HE CPUs (MagnyCours) with 8 cores each
- 2GHz clock frequency
- 16GB RAM (eight 2GB DDR3 modules)

**Characteristics will change with CPU and System architecture.**

## 120MW is 120MW - Is throwing away energy the best we can do?

- Data center needs to be located close to possible consumers
  - Heat requirement average single family home  $150\text{m}^2 * 2.5\text{m}$  (<http://www.haus-bau-blog.de/hausbau-planung/hausbau-deutschland-neubau-einfamilienhaus>)]
  - Outside  $-10^\circ\text{C}$  (inside  $20^\circ\text{C}$ ) 15.66 kW ([https://de.trotec.com/tkl-mieten/infocenter/kapazitaetsberechnungen/heizleistung-berechnen/?tx\\_tkinfo\\_tkinfo\[action\]=heating&tx\\_tkinfo\\_tkinfo\[controller\]=Calculator&cHash=945e1742b4e0b6167df9f8d910f9083](https://de.trotec.com/tkl-mieten/infocenter/kapazitaetsberechnungen/heizleistung-berechnen/?tx_tkinfo_tkinfo[action]=heating&tx_tkinfo_tkinfo[controller]=Calculator&cHash=945e1742b4e0b6167df9f8d910f9083))
  - SuperMUCs (2.4MW) waste heat would be sufficient to heat 153 single family homes under those conditions
  - **120MW == 7662 homes**
- Heat re-use with air cooling and low temperature water is hard

# More Re-Use Possibilities

Currently Running Three Hot Water Cooled Machines at LRZ:

*CoolMUC* at: 41°C IN – 50 to 60°C OUT (load dependent), *SuperMUC I*: 39°C IN – 41 to 44°C OUT, *SuperMUC II*: 40 °C IN – 43 to 47°C OUT

- Ice-Cream production: 30-40°C
- Cloth washing: 40-80°C
- Decaffeinated coffee: 22-100°C
- Surface treatment
  - anodizing 5-42°C
  - plating cooper and steel: 70°C
- Pre-heating of beer: 30-100°C
- Adsorption cooling (currently prototype, production ready installation)
- Beer production: 7-76°C



European Solar Thermal Industry Federation: Key Issues for Renewable Heat in Europe (K4RES-H) Solar Industrial Process Heat; <http://www.estif.org/fileadmin/estif/content/policies/downloads/D23-solar-industrial-process-heat.pdf>

Dr. Vlasta KRMEĽJ, Dipl.Ing. : Selected industrial processes which require low temperature heat; Energy agency of Podavje, Slovenia






# Bringing It All Together



# Temperature Histogram LRZ July 2015 (close to temperature record)





## Maui, Hawaii, US

- **Hottest month: August**
- **Average Evaporation Wet Bulb Temperature: 25°C**
- **Extreme Max. Wet Bulb: 29.4 °C**

Ashrae 2005, Design conditions for KAHULUI, Maui, HI, USA





Don't Forget to Pack your Swimming Trunks!

[Torsten.wilde@lrz.de](mailto:Torsten.wilde@lrz.de)

[www.simopke.de](http://www.simopke.de)



Leibniz-Rechenzentrum  
der Bayerischen Akademie der Wissenschaften

